Water Quality Report

Regulatory Parameters

Sep 2026

East Gippsland Water

BAIRNSDALE

Parameter:	Units:	No. of Samples:	- Results - Monthly Average	Monthly Maximum	12 Month Result #
Escherichia coli	orgs/100mL	6	0	0	0
Total Trihalomethanes	mg/L	1	0.019	0.019	0.074
Turbidity	NTU	6	0.1	0.1	0.1

BEMM RIVER

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.036	0.036	0.079
Turbidity	NTU	5	0.2	0.3	0.2

BUCHAN

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.025	0.025	0.160
Turbidity	NTU	5	0.1	0.1	0.1

CANN RIVER

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.039	0.039	0.093
Turbidity	NTU	5	0.1	0.1	0.2

The Escherichia coli and Total trihalomethane values are a rolling 12 monthly maximum
The turbidity value is a rolling 12 month 95th Percentile

DINNER PLAIN

Parameter:	Units:	No. of Samples:	- Results - Monthly Average	Monthly Maximum	12 Month Result #
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.0	0.0	0.0
Turbidity	NTU	4	0.1	0.1	0.1

EAGLE POINT - PAYNESVILLE

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.025	0.025	0.055
Turbidity	NTU	5	0.1	0.1	0.1

KALIMNA

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.040	0.040	0.078
Turbidity	NTU	4	0.1	0.1	0.1

LINDENOW

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.021	0.021	0.027
Turbidity	NTU	5	0.1	0.1	0.2

LINDENOW SOUTH

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.027	0.027	0.035
Turbidity	NTU	5	0.1	0.2	0.2

The Escherichia coli and Total trihalomethane values are a rolling 12 monthly maximum
The turbidity value is a rolling 12 month 95th Percentile

MALLACOOTA

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.094	0.094	0.150
Turbidity	NTU	5	0.1	0.3	0.9

MERRANGBAUR

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.039	0.039	0.080
Turbidity	NTU	4	0.1	0.2	0.1

METUNG

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.022	0.022	0.057
Turbidity	NTU	4	0.1	0.1	0.1

NICHOLSON - SWAN REACH

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.020	0.020	0.063
Turbidity	NTU	4	0.1	0.1	0.1

NOWA NOWA

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.046	0.046	0.079
Turbidity	NTU	5	0.1	0.1	0.2

The Escherichia coli and Total trihalomet hane values are a rolling 12 monthly maxi mum
The turbidity value is a rolling 12 month 9 5th Percentile

OMEO

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.024	0.024	0.055
Turbidity	NTU	4	0.1	0.1	0.1

ORBOST

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.020	0.015	0.048
Turbidity	NTU	5	0.1	0.1	0.2

SARSFIELD - BRUTHEN

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	5	0	0	0
Total Trihalomethanes	mg/L	1	0.030	0.034	0.074
Turbidity	NTU	5	0.1	0.1	0.1

SUNLAKES - TOORLOO

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.050	0.047	0.089
Turbidity	NTU	4	0.1	0.1	0.1

SWIFTS CREEK

Parameter:	Units:	No. of Samples:			
Escherichia coli	orgs/100mL	4	0	0	0
Total Trihalomethanes	mg/L	1	0.040	0.041	0.089
Turbidity	NTU	4	0.1	0.2	0.1

The Escherichia coli and Total trihalomethane values are a rolling 12 monthly maximum
The turbidity value is a rolling 12 month 95th Percentile

Bairnsdale Results

30/09/2025 30/09/2026

E COLI(C) - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
2/09/2026	124298	MITCHELL\WY YUNG\BAIRNSDALE\342A07 - 119 DREVERMAN STREET	0	ROUTINE	0
9/09/2026	125298	MITCHELL\WY YUNG\BAIRNSDALE\342A08 - 144 WALLACE STREET	0	ROUTINE	0
16/09/2026	136298	MITCHELL\WY YUNG\BAIRNSDALE\342A33 - 38 TIMBARRA DRIVE EASTWOOI	0	ROUTINE	0
23/09/2026	163298	MITCHELL\WY YUNG\WY YUNG\342A22 - 50 BALFOURS ROAD (D/S PUMP)	0	ROUTINE	0
23/09/2026	129298	MITCHELL\WY YUNG\BAIRNSDALE\342A13 - 48 FORGE CREEK ROAD	0	ROUTINE	0
30/09/2026	127298	MITCHELL\WY YUNG\BAIRNSDALE\342A10 - 49 VICTORIA STREET	0	ROUTINE	0

Count	6
Avg	0
Max	0
Annual	0

Total Trihalomethanes - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
16/09/2026	136281	MITCHELL\WY YUNG\BAIRNSDALE\342A33 - 38 TIMBARRA DRIVE EASTWOOI	0.019	ROUTINE	0.019

Count	1
Avg	0.019
Max	0.019
Annual	0.074

Turbidity - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
2/09/2026	124143	MITCHELL\WY YUNG\BAIRNSDALE\342A07 - 119 DREVERMAN STREET	0.10	ROUTINE	0.10
9/09/2026	125143	MITCHELL\WY YUNG\BAIRNSDALE\342A08 - 144 WALLACE STREET	0.10	ROUTINE	0.10
16/09/2026	136143	MITCHELL\WY YUNG\BAIRNSDALE\342A33 - 38 TIMBARRA DRIVE EASTWOOI	0.10	ROUTINE	0.10
23/09/2026	129143	MITCHELL\WY YUNG\BAIRNSDALE\342A13 - 48 FORGE CREEK ROAD	0.10	ROUTINE	0.10
23/09/2026	163143	MITCHELL\WY YUNG\WY YUNG\342A22 - 50 BALFOURS ROAD (D/S PUMP)	0.10	ROUTINE	0.10
30/09/2026	127143	MITCHELL\WY YUNG\BAIRNSDALE\342A10 - 49 VICTORIA STREET	0.10	ROUTINE	0.10

Count	6
Avg	0.10
Max	0.10
Annual	0.10

BEMM RIVER Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	609298	BEMM RIVER\RETICULATION\337A07 - 41 SYDENHAM PDE	0	ROUTINE	0
8/09/2026	610298	BEMM RIVER\RETICULATION\337A08 - 10 KATHLEEN DRV	0	ROUTINE	0
15/09/2026	608298	BEMM RIVER\RETICULATION\337A05 - 14 BORONIA ST (1ST ON LEFT)	0	ROUTINE	0
22/09/2026	611298	BEMM RIVER\RETICULATION\337A09 - 9 SYDNEHAM PDE	0	ROUTINE	0
29/09/2026	609298	BEMM RIVER\RETICULATION\337A07 - 41 SYDENHAM PDE	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
8/09/2026	610281	BEMM RIVER\RETICULATION\337A08 - 10 KATHLEEN DRV	0.036	ROUTINE	0.036
				Count	1
				Avg	0.036
				Max	0.036
				Annual	0.079

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	609143	BEMM RIVER\RETICULATION\337A07 - 41 SYDENHAM PDE	0.30	ROUTINE	0.30
8/09/2026	610143	BEMM RIVER\RETICULATION\337A08 - 10 KATHLEEN DRV	0.10	ROUTINE	0.10
15/09/2026	608143	BEMM RIVER\RETICULATION\337A05 - 14 BORONIA ST (1ST ON LEFT)	0.10	ROUTINE	0.10
22/09/2026	611143	BEMM RIVER\RETICULATION\337A09 - 9 SYDNEHAM PDE	0.10	ROUTINE	0.10
29/09/2026	609143	BEMM RIVER\RETICULATION\337A07 - 41 SYDENHAM PDE	0.20	ROUTINE	0.20
				Count	5
				Avg	0.16
				Max	0.30
				Annual	0.25

Buchan Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
3/09/2026	660298	BUCHAN\RETICULATION\338A01 - 5622 ORBOST - BUCHAN ROAD (First house	0	ROUTINE	0
10/09/2026	662298	BUCHAN\RETICULATION\338A03 - 65 MAIN STREET (Conorville)	0	ROUTINE	0
17/09/2026	661298	BUCHAN\RETICULATION\338A02 - 37 MAIN STREET (Police Residence)	0	ROUTINE	0
23/09/2026	660298	BUCHAN\RETICULATION\338A01 - 5622 ORBOST - BUCHAN ROAD (First house	0	ROUTINE	0
30/09/2026	663298	BUCHAN\RETICULATION\338A05 - 1 ARMSTRONG STREET (Behind School)	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
10/09/2026	662281	BUCHAN\RETICULATION\338A03 - 65 MAIN STREET (Conorville)	0.025	ROUTINE	0.025
				Count	1
				Avg	0.025
				Max	0.025
				Annual	0.160

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
3/09/2026	660143	BUCHAN\RETICULATION\338A01 - 5622 ORBOST - BUCHAN ROAD (First house	0.10	ROUTINE	0.10
10/09/2026	662143	BUCHAN\RETICULATION\338A03 - 65 MAIN STREET (Conorville)	0.10	ROUTINE	0.10
17/09/2026	661143	BUCHAN\RETICULATION\338A02 - 37 MAIN STREET (Police Residence)	0.10	ROUTINE	0.10
23/09/2026	660143	BUCHAN\RETICULATION\338A01 - 5622 ORBOST - BUCHAN ROAD (First house	0.10	ROUTINE	0.10
30/09/2026	663143	BUCHAN\RETICULATION\338A05 - 1 ARMSTRONG STREET (Behind School)	0.10	ROUTINE	0.10
				Count	5
				Avg	0.10
				Max	0.10
				Annual	0.10

Bainsdale Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	812298	CANN RIVER\RETICULATION\330A04 - 2 BAUM STREET	0	ROUTINE	0
8/09/2026	811298	CANN RIVER\RETICULATION\330A03 - MONARO HWY (NEXT TO GALLERY)	0	ROUTINE	0
15/09/2026	810298	CANN RIVER\RETICULATION\330A01 - 14 PRINCES HWY (Behind Supermarket)	0	ROUTINE	0
22/09/2026	813298	CANN RIVER\RETICULATION\330A05 - 12 TAMBOON ROAD (CFA Shed)	0	ROUTINE	0
29/09/2026	814298	CANN RIVER\RETICULATION\330A06 - 70 PRINCES HWY	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
8/09/2026	811281	CANN RIVER\RETICULATION\330A03 - MONARO HWY (NEXT TO GALLERY)	0.039	ROUTINE	0.039
				Count	1
				Avg	0.039
				Max	0.039
				Annual	0.093

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	812143	CANN RIVER\RETICULATION\330A04 - 2 BAUM STREET	0.10	ROUTINE	0.10
8/09/2026	811143	CANN RIVER\RETICULATION\330A03 - MONARO HWY (NEXT TO GALLERY)	0.10	ROUTINE	0.10
15/09/2026	810143	CANN RIVER\RETICULATION\330A01 - 14 PRINCES HWY (Behind Supermarket)	0.10	ROUTINE	0.10
22/09/2026	813143	CANN RIVER\RETICULATION\330A05 - 12 TAMBOON ROAD (CFA Shed)	0.10	ROUTINE	0.10
29/09/2026	814143	CANN RIVER\RETICULATION\330A06 - 70 PRINCES HWY	0.10	ROUTINE	0.10
				Count	5
				Avg	0.10
				Max	0.10
				Annual	0.20

Dinner Plain Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	960298	DINNER PLAIN\RETICULATION\331A01 - DRYBONE LANE (UMBELS)	0	ROUTINE	0
14/09/2026	962298	DINNER PLAIN\RETICULATION\331A03 - 23 GEEBUNG DRIVE (YAK & YETI)	0	ROUTINE	0
21/09/2026	964298	DINNER PLAIN\RETICULATION\331A05 - ALPINE SCHOOL	0	ROUTINE	0
28/09/2026	963298	DINNER PLAIN\RETICULATION\331A04 - HALTER LANE (COLORADO)	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	960533	DINNER PLAIN\RETICULATION\331A01 - DRYBONE LANE (UMBELS)	0.0010	ROUTINE	0.00
				Count	1
				Avg	0.000
				Max	0.001
				Annual	0.001

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	960143	DINNER PLAIN\RETICULATION\331A01 - DRYBONE LANE (UMBELS)	0.10	ROUTINE	0.10
14/09/2026	962143	DINNER PLAIN\RETICULATION\331A03 - 23 GEEBUNG DRIVE (YAK & YETI)	0.10	ROUTINE	0.10
21/09/2026	964143	DINNER PLAIN\RETICULATION\331A05 - ALPINE SCHOOL	0.10	ROUTINE	0.10
28/09/2026	963143	DINNER PLAIN\RETICULATION\331A04 - HALTER LANE (COLORADO)	0.10	ROUTINE	0.10
				Count	4
				Avg	0.10
				Max	0.10
				Annual	0.10

Eagle Point - Paynseville Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
2/09/2026	217298	MITCHELL\EAGLE POINT\EAGLE POINT\334A17 - 8 WHITE CRT	0	ROUTINE	0
9/09/2026	218298	MITCHELL\EAGLE POINT\EAGLE POINT\334A18 - 2 GREEN CRT	0	ROUTINE	0
16/09/2026	224298	MITCHELL\EAGLE POINT\EAGLE POINT\334A25 - 61 SCHOOL ROAD (OLD 334	0	ROUTINE	0
23/09/2026	219298	MITCHELL\EAGLE POINT\EAGLE POINT\334A19 - 13 MILLICENT CRT	0	ROUTINE	0
30/09/2026	220298	MITCHELL\EAGLE POINT\EAGLE POINT\334A20 - 29 BAY RD (OLD 342A25)	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
16/09/2026	224281	MITCHELL\EAGLE POINT\EAGLE POINT\334A25 - 61 SCHOOL ROAD (OLD 334	0.025	ROUTINE	0.025
				Count	1
				Avg	0.025
				Max	0.025
				Annual	0.055

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
2/09/2026	217143	MITCHELL\EAGLE POINT\EAGLE POINT\334A17 - 8 WHITE CRT	0.10	ROUTINE	0.10
9/09/2026	218143	MITCHELL\EAGLE POINT\EAGLE POINT\334A18 - 2 GREEN CRT	0.10	ROUTINE	0.10
16/09/2026	224143	MITCHELL\EAGLE POINT\EAGLE POINT\334A25 - 61 SCHOOL ROAD (OLD 334	0.10	ROUTINE	0.10
23/09/2026	219143	MITCHELL\EAGLE POINT\EAGLE POINT\334A19 - 13 MILLICENT CRT	0.10	ROUTINE	0.10
30/09/2026	220143	MITCHELL\EAGLE POINT\EAGLE POINT\334A20 - 29 BAY RD (OLD 342A25)	0.10	ROUTINE	0.10
				Count	5
				Avg	0.10
				Max	0.10
				Annual	0.13

Kalimna Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	325298	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C06 - 5 MARGARET CRT	0	ROUTINE	0
14/09/2026	322298	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C03 - 52 HAZEL RD	0	ROUTINE	0
21/09/2026	326298	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C07 - 5 TAMBO CRT	0	ROUTINE	0
28/09/2026	324298	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C05 - 48 POINTS RD	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	325281	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C06 - 5 MARGARET CRT	0.040	ROUTINE	0.040
				Count	1
				Avg	0.040
				Max	0.040
				Annual	0.078

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	325143	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C06 - 5 MARGARET CRT	0.10	ROUTINE	0.10
14/09/2026	322143	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C03 - 52 HAZEL RD	0.10	ROUTINE	0.10
21/09/2026	326143	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C07 - 5 TAMBO CRT	0.10	ROUTINE	0.10
28/09/2026	324143	MITCHELL\SUNLAKES - TOORLOO\KALIMNA\343C05 - 48 POINTS RD	0.10	ROUTINE	0.10
				Count	4
				Avg	0.10
				Max	0.10
				Annual	0.10

Lindenow Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
2/09/2026	108298	MITCHELL\LINDENOW\WALPA\335A03 - OUTSIDE 1535 DARGO ROAD	0	ROUTINE	0
9/09/2026	104298	MITCHELL\LINDENOW\335A05 - 71 MAIN RD	0	ROUTINE	0
16/09/2026	102298	MITCHELL\LINDENOW\335A04 - 108 HENRY STREET (CFA shed)	0	ROUTINE	0
23/09/2026	108298	MITCHELL\LINDENOW\WALPA\335A03 - OUTSIDE 1535 DARGO ROAD	0	ROUTINE	0
30/09/2026	101298	MITCHELL\LINDENOW\335A01 - 17 CHURCH STREET	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
16/09/2026	102281	MITCHELL\LINDENOW\335A04 - 108 HENRY STREET (CFA shed)	0.021	ROUTINE	0.021
				Count	1
				Avg	0.021
				Max	0.021
				Annual	0.027

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
2/09/2026	108143	MITCHELL\LINDENOW\WALPA\335A03 - OUTSIDE 1535 DARGO ROAD	0.10	ROUTINE	0.10
9/09/2026	104143	MITCHELL\LINDENOW\335A05 - 71 MAIN RD	0.10	ROUTINE	0.10
16/09/2026	102143	MITCHELL\LINDENOW\335A04 - 108 HENRY STREET (CFA shed)	0.10	ROUTINE	0.10
23/09/2026	108143	MITCHELL\LINDENOW\WALPA\335A03 - OUTSIDE 1535 DARGO ROAD	0.10	ROUTINE	0.10
30/09/2026	101143	MITCHELL\LINDENOW\335A01 - 17 CHURCH STREET	0.10	ROUTINE	0.10
				Count	5
				Avg	0.10
				Max	0.10
				Annual	0.20

Lindenow South Results

30/09/2025 30/09/2026

E COLI(C) - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
2/09/2026	113298	MITCHELL\LINDENOW SOUTH\335B03 - FERNBANK RD (OPP. FOOTY GND)	0	ROUTINE	0
9/09/2026	114298	MITCHELL\LINDENOW SOUTH\335B05 - 646 GLENALADALE RD (ON FENCE)	0	ROUTINE	0
16/09/2026	115298	MITCHELL\LINDENOW SOUTH\335B06 - LINDENOW SOUTH SCHOOL	0	ROUTINE	0
23/09/2026	116298	MITCHELL\LINDENOW SOUTH\335B07 - 606 LINDENOW - GLENALADALE ROA	0	ROUTINE	0
30/09/2026	113298	MITCHELL\LINDENOW SOUTH\335B03 - FERNBANK RD (OPP. FOOTY GND)	0	ROUTINE	0

Count	5
Avg	0
Max	0
Annual	0

Total Trihalomethanes - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
16/09/2026	115281	MITCHELL\LINDENOW SOUTH\335B06 - LINDENOW SOUTH SCHOOL	0.027	ROUTINE	0.027

Count	1
Avg	0.027
Max	0.027
Annual	0.035

Turbidity - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
2/09/2026	113143	MITCHELL\LINDENOW SOUTH\335B03 - FERNBANK RD (OPP. FOOTY GND)	0.10	ROUTINE	0.10
9/09/2026	114143	MITCHELL\LINDENOW SOUTH\335B05 - 646 GLENALADALE RD (ON FENCE)	0.10	ROUTINE	0.10
16/09/2026	115143	MITCHELL\LINDENOW SOUTH\335B06 - LINDENOW SOUTH SCHOOL	0.20	ROUTINE	0.20
23/09/2026	116143	MITCHELL\LINDENOW SOUTH\335B07 - 606 LINDENOW - GLENALADALE ROA	0.10	ROUTINE	0.10
30/09/2026	113143	MITCHELL\LINDENOW SOUTH\335B03 - FERNBANK RD (OPP. FOOTY GND)	0.10	ROUTINE	0.10

Count	5
Avg	0.12
Max	0.20
Annual	0.20

Mallacoota Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	721298	MALLACOOTA\RETICULATION\339A02 - CAMP PARK WHARF	0	ROUTINE	0
8/09/2026	732298	MALLACOOTA\RETICULATION\339A04 - 6 SCHNAPPER POINT DRIVE	0	ROUTINE	0
15/09/2026	731298	MALLACOOTA\RETICULATION\339A05 - 38 KARBETHONG AVE	0	ROUTINE	0
22/09/2026	740298	MALLACOOTA\RETICULATION\339A10 - 16 STINGRAY POINT DVE	0	ROUTINE	0
29/09/2026	741298	MALLACOOTA\RETICULATION\339A09 - 19 RAHEEN DRIVE	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
8/09/2026	732281	MALLACOOTA\RETICULATION\339A04 - 6 SCHNAPPER POINT DRIVE	0.094	ROUTINE	0.094
				Count	1
				Avg	0.094
				Max	0.094
				Annual	0.150

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	721143	MALLACOOTA\RETICULATION\339A02 - CAMP PARK WHARF	0.30	ROUTINE	0.30
8/09/2026	732143	MALLACOOTA\RETICULATION\339A04 - 6 SCHNAPPER POINT DRIVE	0.10	ROUTINE	0.10
15/09/2026	731143	MALLACOOTA\RETICULATION\339A05 - 38 KARBETHONG AVE	0.10	ROUTINE	0.10
22/09/2026	740143	MALLACOOTA\RETICULATION\339A10 - 16 STINGRAY POINT DVE	0.10	ROUTINE	0.10
29/09/2026	741143	MALLACOOTA\RETICULATION\339A09 - 19 RAHEEN DRIVE	0.10	ROUTINE	0.10
				Count	5
				Avg	0.14
				Max	0.30
				Annual	0.89

Merrangbaur Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	299298	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343B03 - 56 OCEAN VIE	0	ROUTINE	0
14/09/2026	294298	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\MERRANGBAUR\343B0	0	ROUTINE	0
21/09/2026	295298	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\MERRANGBAUR\343B0	0	ROUTINE	0
28/09/2026	353298	MITCHELL\SUNLAKES - TOORLOO\LAKE TYERS BEACH\343B07 - 355 LAKE TY	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	299281	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343B03 - 56 OCEAN VIE	0.039	ROUTINE	0.039
				Count	1
				Avg	0.039
				Max	0.039
				Annual	0.080

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	299143	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343B03 - 56 OCEAN VIE	0.20	ROUTINE	0.20
14/09/2026	294143	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\MERRANGBAUR\343B0	0.10	ROUTINE	0.10
21/09/2026	295143	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\MERRANGBAUR\343B0	0.10	ROUTINE	0.10
28/09/2026	353143	MITCHELL\SUNLAKES - TOORLOO\LAKE TYERS BEACH\343B07 - 355 LAKE TY	0.10	ROUTINE	0.10
				Count	4
				Avg	0.13
				Max	0.20
				Annual	0.10

Metung Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	196298	MITCHELL\METUNG\336B02 - 21 WOOD ST (HIGH LEVEL)	0	ROUTINE	0
14/09/2026	201298	MITCHELL\METUNG\336B10 - 3 PETER ROAD	0	ROUTINE	0
21/09/2026	195298	MITCHELL\METUNG\336B01 - 29 STIRLING RD (LOW LEVEL)	0	ROUTINE	0
28/09/2026	200298	MITCHELL\METUNG\336B09 - 30 SHAVING POINT RD	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
14/09/2026	201281	MITCHELL\METUNG\336B10 - 3 PETER ROAD	0.022	ROUTINE	0.022
				Count	1
				Avg	0.022
				Max	0.022
				Annual	0.057

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	196143	MITCHELL\METUNG\336B02 - 21 WOOD ST (HIGH LEVEL)	0.10	ROUTINE	0.10
14/09/2026	201143	MITCHELL\METUNG\336B10 - 3 PETER ROAD	0.10	ROUTINE	0.10
21/09/2026	195143	MITCHELL\METUNG\336B01 - 29 STIRLING RD (LOW LEVEL)	0.10	ROUTINE	0.10
28/09/2026	200143	MITCHELL\METUNG\336B09 - 30 SHAVING POINT RD	0.10	ROUTINE	0.10
				Count	4
				Avg	0.10
				Max	0.10
				Annual	0.10

Nicholson-Swan Reach Results

30/09/2025 30/09/2026

E COLI(C) - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
7/09/2026	268298	MITCHELL\NICHOLSON - SWAN REACH\NICHOLSON\336A09 - 15 BRADLEY C	0	ROUTINE	0
14/09/2026	276298	MITCHELL\NICHOLSON - SWAN REACH\SWAN REACH\336A11 - 71 OLD ORBC	0	ROUTINE	0
21/09/2026	288298	MITCHELL\NICHOLSON - SWAN REACH\JOHNSONVILLE\336A14 - LOT 6 PUNT	0	ROUTINE	0
28/09/2026	286298	MITCHELL\NICHOLSON - SWAN REACH\JOHNSONVILLE\336A02 - 24 PUNT RC	0	ROUTINE	0

Count	4
Avg	0
Max	0
Annual	0

Total Trihalomethanes - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
14/09/2026	276281	MITCHELL\NICHOLSON - SWAN REACH\SWAN REACH\336A11 - 71 OLD ORBC	0.020	ROUTINE	0.020

Count	1
Avg	0.020
Max	0.020
Annual	0.063

Turbidity - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
7/09/2026	268143	MITCHELL\NICHOLSON - SWAN REACH\NICHOLSON\336A09 - 15 BRADLEY C	0.10	ROUTINE	0.10
14/09/2026	276143	MITCHELL\NICHOLSON - SWAN REACH\SWAN REACH\336A11 - 71 OLD ORBC	0.10	ROUTINE	0.10
21/09/2026	288143	MITCHELL\NICHOLSON - SWAN REACH\JOHNSONVILLE\336A14 - LOT 6 PUNT	0.10	ROUTINE	0.10
28/09/2026	286143	MITCHELL\NICHOLSON - SWAN REACH\JOHNSONVILLE\336A02 - 24 PUNT RC	0.10	ROUTINE	0.10

Count	4
Avg	0.10
Max	0.10
Annual	0.10

Nowa Nowa Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	336298	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A06 - 25 WANDIN WAY	0	ROUTINE	0
8/09/2026	338298	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A09 - FARMERS COTTAG	0	ROUTINE	0
15/09/2026	336298	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A06 - 25 WANDIN WAY	0	ROUTINE	0
22/09/2026	334298	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A04 - 2028 PRINCES HW	0	ROUTINE	0
29/09/2026	335298	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A05 - 32 NOWA NOWA -	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
8/09/2026	338281	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A09 - FARMERS COTTAG	0.046	ROUTINE	0.046
				Count	1
				Avg	0.046
				Max	0.046
				Annual	0.079

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	336143	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A06 - 25 WANDIN WAY	0.10	ROUTINE	0.10
8/09/2026	338143	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A09 - FARMERS COTTAG	0.10	ROUTINE	0.10
15/09/2026	336143	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A06 - 25 WANDIN WAY	0.10	ROUTINE	0.10
22/09/2026	334143	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A04 - 2028 PRINCES HW	0.10	ROUTINE	0.10
29/09/2026	335143	MITCHELL\SUNLAKES - TOORLOO\NOWA NOWA\341A05 - 32 NOWA NOWA -	0.10	ROUTINE	0.10
				Count	5
				Avg	0.10
				Max	0.10
				Annual	0.19

Omeo Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	863298	OMEO\RETICULATION\344A08 - CWA HALL. DAY AVE (LOW LEVEL)	0	ROUTINE	0
14/09/2026	859298	OMEO\RETICULATION\344A04 - 41 PARK STREET (beside Motel)	0	ROUTINE	0
21/09/2026	858298	OMEO\RETICULATION\344A01 - BILTON STREET (Cemetery)	0	ROUTINE	0
28/09/2026	862298	OMEO\RETICULATION\344A07 - 8 CREEK ST	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	863281	OMEO\RETICULATION\344A08 - CWA HALL. DAY AVE (LOW LEVEL)	0.024	ROUTINE	0.024
				Count	1
				Avg	0.024
				Max	0.024
				Annual	0.055

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	863143	OMEO\RETICULATION\344A08 - CWA HALL. DAY AVE (LOW LEVEL)	0.10	ROUTINE	0.10
14/09/2026	859143	OMEO\RETICULATION\344A04 - 41 PARK STREET (beside Motel)	0.10	ROUTINE	0.10
21/09/2026	858143	OMEO\RETICULATION\344A01 - BILTON STREET (Cemetery)	0.10	ROUTINE	0.10
28/09/2026	862143	OMEO\RETICULATION\344A07 - 8 CREEK ST	0.10	ROUTINE	0.10
				Count	4
				Avg	0.10
				Max	0.10
				Annual	0.10

Orbost Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	569298	ORBOST\RETICULATION\ORBOST\340A20 - 120 FOREST RD	0	ROUTINE	0
8/09/2026	568298	ORBOST\RETICULATION\ORBOST\340A19 - 122 STANLEY ST	0	ROUTINE	0
15/09/2026	560298	ORBOST\RETICULATION\ORBOST\340A01 - 11 CLARKE STREET	0	ROUTINE	0
22/09/2026	562298	ORBOST\RETICULATION\ORBOST\340A07 - 26 TYNDALL STREET (Garden Sup	0	ROUTINE	0
29/09/2026	565298	ORBOST\RETICULATION\ORBOST\340A12 - 34 HAMILTON STREET	0	ROUTINE	0
				Count	5
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
8/09/2026	568281	ORBOST\RETICULATION\ORBOST\340A19 - 122 STANLEY ST	0.02	ROUTINE	0.02
				Count	1
				Avg	0.020
				Max	0.015
				Annual	0.048

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
1/09/2026	569143	ORBOST\RETICULATION\ORBOST\340A20 - 120 FOREST RD	0.10	ROUTINE	0.10
8/09/2026	568143	ORBOST\RETICULATION\ORBOST\340A19 - 122 STANLEY ST	0.10	ROUTINE	0.10
15/09/2026	560143	ORBOST\RETICULATION\ORBOST\340A01 - 11 CLARKE STREET	0.10	ROUTINE	0.10
22/09/2026	562143	ORBOST\RETICULATION\ORBOST\340A07 - 26 TYNDALL STREET (Garden Sup	0.10	ROUTINE	0.10
29/09/2026	565143	ORBOST\RETICULATION\ORBOST\340A12 - 34 HAMILTON STREET	0.10	ROUTINE	0.10
				Count	5
				Avg	0.10
				Max	0.10
				Annual	0.20

Sarsfield - Bruthen Results

30/09/2025 30/09/2026

E COLI(C) - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
3/09/2026	172298	MITCHELL\SARSFIELD - BRUTHEN\BRUTHEN\332A03 - 213 OMEO H/WAY HIG	0	ROUTINE	0
10/09/2026	186298	MITCHELL\SARSFIELD - BRUTHEN\MOSSIFACE\332A02 - MOSSIFACE-SWAN	0	ROUTINE	0
17/09/2026	173298	MITCHELL\SARSFIELD - BRUTHEN\BRUTHEN\332A09 - 129 CHAMBERS RD (H	0	ROUTINE	0
23/09/2026	182298	MITCHELL\SARSFIELD - BRUTHEN\SARSFIELD\332A11 - 50 HIGH ST (Sarsfield	0	ROUTINE	0
30/09/2026	181298	MITCHELL\SARSFIELD - BRUTHEN\SARSFIELD\332A08 - OMEO HWY (DUNCA	0	ROUTINE	0

Count	5
Avg	0
Max	0
Annual	0

Total Trihalomethanes - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
10/09/2026	186281	MITCHELL\SARSFIELD - BRUTHEN\MOSSIFACE\332A02 - MOSSIFACE-SWAN	0.03	ROUTINE	0.03

Count	1
Avg	0.030
Max	0.034
Annual	0.074

Turbidity - Monthly

Date	VarNum	Location Path	Result	Sampling Type	Result to use
3/09/2026	172143	MITCHELL\SARSFIELD - BRUTHEN\BRUTHEN\332A03 - 213 OMEO H/WAY HIG	0.10	ROUTINE	0.10
10/09/2026	186143	MITCHELL\SARSFIELD - BRUTHEN\MOSSIFACE\332A02 - MOSSIFACE-SWAN	0.10	ROUTINE	0.10
17/09/2026	173143	MITCHELL\SARSFIELD - BRUTHEN\BRUTHEN\332A09 - 129 CHAMBERS RD (H	0.10	ROUTINE	0.10
23/09/2026	182143	MITCHELL\SARSFIELD - BRUTHEN\SARSFIELD\332A11 - 50 HIGH ST (Sarsfield	0.10	ROUTINE	0.10
30/09/2026	181143	MITCHELL\SARSFIELD - BRUTHEN\SARSFIELD\332A08 - OMEO HWY (DUNCA	0.10	ROUTINE	0.10

Count	5
Avg	0.10
Max	0.10
Annual	0.15

Sunlakes Toorloo Results

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	351298	MITCHELL\SUNLAKES - TOORLOO\LAKE TYERS BEACH\343A03 - 13 OUTLOO	0	ROUTINE	0
14/09/2026	309298	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343A17 - 7 HASSETT R	0	ROUTINE	0
21/09/2026	301298	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343A06 - 52 NAUTILUS	0	ROUTINE	0
28/09/2026	300298	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343A05 - 25 VIEW STRI	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	351281	MITCHELL\SUNLAKES - TOORLOO\LAKE TYERS BEACH\343A03 - 13 OUTLOO	0.05	ROUTINE	0.05
				Count	1
				Avg	0.050
				Max	0.047
				Annual	0.089

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	351143	MITCHELL\SUNLAKES - TOORLOO\LAKE TYERS BEACH\343A03 - 13 OUTLOO	0.10	ROUTINE	0.10
14/09/2026	309143	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343A17 - 7 HASSETT R	0.10	ROUTINE	0.10
21/09/2026	301143	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343A06 - 52 NAUTILUS	0.10	ROUTINE	0.10
28/09/2026	300143	MITCHELL\SUNLAKES - TOORLOO\LAKES ENTRANCE\343A05 - 25 VIEW STRI	0.10	ROUTINE	0.10
				Count	4
				Avg	0.10
				Max	0.10
				Annual	0.10

DinnerPlain!F$49

30/09/2025 30/09/2026

E COLI(C) - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	908298	SWIFTS CREEK\RETICULATION\333A05 - 6835 GREAT ALPINE RD (First Mill Hc	0	ROUTINE	0
14/09/2026	905298	SWIFTS CREEK\RETICULATION\333A01 - 6923 GREAT ALPINE RD (TELSTRA)	0	ROUTINE	0
21/09/2026	907298	SWIFTS CREEK\RETICULATION\333A04 - 19 McMILLAN ST (BUSH NURSING C	0	ROUTINE	0
28/09/2026	908298	SWIFTS CREEK\RETICULATION\333A05 - 6835 GREAT ALPINE RD (First Mill Hc	0	ROUTINE	0
				Count	4
				Avg	0
				Max	0
				Annual	0

Total Trihalomethanes - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	908281	SWIFTS CREEK\RETICULATION\333A05 - 6835 GREAT ALPINE RD (First Mill Hc	0.04	ROUTINE	0.04
				Count	1
				Avg	0.040
				Max	0.041
				Annual	0.089

Turbidity - Monthly					
Date	**VarNum**	**Location Path**	**Result**	**Sampling Type**	**Result to use**
7/09/2026	908143	SWIFTS CREEK\RETICULATION\333A05 - 6835 GREAT ALPINE RD (First Mill Hc	0.10	ROUTINE	0.10
14/09/2026	905143	SWIFTS CREEK\RETICULATION\333A01 - 6923 GREAT ALPINE RD (TELSTRA)	0.10	ROUTINE	0.10
21/09/2026	907143	SWIFTS CREEK\RETICULATION\333A04 - 19 McMILLAN ST (BUSH NURSING C	0.10	ROUTINE	0.10
28/09/2026	908143	SWIFTS CREEK\RETICULATION\333A05 - 6835 GREAT ALPINE RD (First Mill Hc	0.20	ROUTINE	0.20
				Count	4
				Avg	0.13
				Max	0.20
				Annual	0.10